

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 3

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-08374  
Name of Facility: Madison Middle School  
Address: 3400 NW 87 Street  
City, Zip: Miami 33147

**Correct By: Next Inspection**  
**Re-Inspection Date: None**

Type: Public Schools  
Owner: M-DCSB Food and Nutrition  
Person In Charge: Anthony Simons Phone: (305) 836-2610  
PIC Email: 227219@dadeschools.net

**Inspection Information**

Purpose: Routine  
Inspection Date: 3/7/2023

Begin Time: 02:00 PM  
End Time: 02:58 PM

**Additional Information**

FEMALES ..... 212  
MALES ..... 230

CENSUS ..... 442

*This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

**Violation Markings**

SCHOOL SANITATION	<b>IN</b>	11. Group Toilet Rooms	<b>IN</b>	21. Pest Control
<b>IN</b> 1. School Site	<b>OUT</b>	12. Toilet Facilities		SAFETY
<b>IN</b> 2. Playground, Equip & Athletic Fields*	<b>OUT</b>	13. Handwashing Facilities	<b>IN</b>	22. First Aid Kit
<b>NA</b> 3. Athletic & Playground Equipment	<b>OUT</b>	14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<b>NA</b>	15. Shower Facilities	<b>NA</b>	23. Sanitizers
<b>IN</b> 4. Construction	<b>NA</b>	16. Showers Water Temperatures	<b>NA</b>	24. Changing Station & Mats
<b>OUT</b> 5. Maintenance & Repair		WATER SUPPLY	<b>NA</b>	25. Hand Sink
<b>IN</b> 6. Lighting Standards	<b>IN</b>	17. Approved Source	<b>NA</b>	26. Garbage Can
<b>IN</b> 7. Heating, Ventilation, A/C Standards	<b>IN</b>	18. Drinking Fountains		ANIMAL HEALTH & SAFETY
<b>IN</b> 8. Natural Ventilation		LIQUID WASTE & WASTE WATER	<b>NA</b>	27. Animal Maintenance/Aggressive
<b>OUT</b> 9. Mechanical Ventilation	<b>IN</b>	19. Sewage Disposal		DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<b>IN</b>	20. Solid Waste	<b>NA</b>	28. Maintenance/Complaint
<b>IN</b> 10. Provided/Accessible/Separation		PEST CONTROL	<b>NA</b>	29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: \* = 2. Playground, Equipment & Athletic Fields

**General Comments**

Satisfactory

Email Address(es): 237643@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 3

**Violations Comments**

**Violation #5. Maintenance & Repair**

Observed ceiling lighting fixtures with light tubes burn out in Classrooms 14, 61 and 62. Replace light tubes.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

**Violation #9. Mechanical Ventilation**

Observed exhaust ventilation system not functioning in Restrooms 1401 and 1403. Repair/Replace exhaust ventilation system.

CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.

**Violation #12. Toilet Facilities**

Observed cracked toilet in Boy's Restroom Building 4. Replace toilet.

Observed urinal not flushing in Boy's Restroom Building 3 and Restroom 1403. Repair urinals.

Observed two urinals clogged in Boy's Restroom. Unclog urinals.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

**Violation #13. Handwashing Facilities**

Observed handwashing sinks in disrepair in Restrooms 1403 and Boy's Restroom. Repair handwashing sinks.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

**Violation #14. Soap Dispensers**

Observes missing soap dispensers in Girl's Restroom Building 1, Boy's Restroom Building 4. Provide soap dispensers.

CODE REFERENCE: 14. Soap Dispensers. 468.3.5.7.2 FBC. Soap dispensers for liquid, foam or powdered soap shall be provided at all handwashing basins. 5(10)(f) SREF. Dispensers for liquid, foam, or powdered soap shall be maintained in a safe & secure condition at all times.

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



3 of 3

Inspection Conducted By: Vicente Prietodiaz (31113)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name: Sharlesque George  
Date: 3/7/2023

Inspector Signature:

Handwritten signature of the inspector, Vicente Prietodiaz.

Client Signature:

Handwritten signature of the client, Sharlesque George.